DEPARTMENT OF HEALTH AND HUMAN SERVICES CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 07/09/2015 FORM APPROVED OMB NO. 0938-0391

OF DEFICIENCIES F CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	I ` ′	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01		(X3) DATE SURVEY COMPLETED	
15G433		B. WING			07/07/2015	
NAME OF PROVIDER OR SUPPLIER REM-INDIANA INC			STREET ADDRESS, CITY, STATE, ZIP CODE 3938 PRANGE AVE LAFAYETTE, IN 47905			
D SUMMARY STATEMENT OF DEFICIENCIES IX (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)		ID PREFIX TAG	(EACH CORRECTIVE ACTION	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		
0 INITIAL COMMENTS		К0	00			
A Life Safety Code Recertification Survey was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.470(j).						
Survey Date: 07/07/15						
Facility Number: 000947 Provider Number: 15G433 AIM Number: 100244580						
At this Life Safety Code survey, REM-Indiana Inc. was found in compliance with Requirements for Participation in Medicaid, 42 CFR subpart 483.470(j), Life Safety from Fire, and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 33, Existing Residential Board and Care Occupancies.						
facility has a fire alarr detection in the corrid and hard wired smoke sleeping rooms. The	n system with smoke lors, common living areas e detectors in all client facility has a capacity of					
(E-Score) using NFPA Approaches to Life Sa	A 101 A, Alternative afety, Chapter 6, rated the					
	ROVIDER OR SUPPLIER ANA INC SUMMARY ST. (EACH DEFICIENC REGULATORY OR I INITIAL COMMENTS A Life Safety Code R conducted by the Indi Health in accordance Survey Date: 07/07/2 Facility Number: 000 Provider Number: 15 AIM Number: 10024 At this Life Safety Cowas found in complia Participation in Medic 483.470(j), Life Safety edition of the National (NFPA) 101, Life Safety edition of the National NFPA 101, L	ANA INC SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION) INITIAL COMMENTS A Life Safety Code Recertification Survey was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.470(j). Survey Date: 07/07/15 Facility Number: 000947 Provider Number: 15G433 AIM Number: 100244580 At this Life Safety Code survey, REM-Indiana Inc. was found in compliance with Requirements for Participation in Medicaid, 42 CFR subpart 483.470(j), Life Safety from Fire, and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 33, Existing Residential Board and Care Occupancies. This one story facility was sprinklered. The facility has a fire alarm system with smoke detection in the corridors, common living areas and hard wired smoke detectors in all client sleeping rooms. The facility has a capacity of eight and had a census of seven at the time of	ROVIDER OR SUPPLIER ANA INC SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION) INITIAL COMMENTS A Life Safety Code Recertification Survey was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.470(j). Survey Date: 07/07/15 Facility Number: 000947 Provider Number: 15G433 AIM Number: 100244580 At this Life Safety Code survey, REM-Indiana Inc. was found in compliance with Requirements for Participation in Medicaid, 42 CFR subpart 483.470(j), Life Safety from Fire, and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 33, Existing Residential Board and Care Occupancies. This one story facility was sprinklered. The facility has a fire alarm system with smoke detection in the corridors, common living areas and hard wired smoke detectors in all client sleeping rooms. The facility has a capacity of eight and had a census of seven at the time of this survey. Calculation of the Evacuation Difficulty Score (E-Score) using NFPA 101 A, Alternative Approaches to Life Safety, Chapter 6, rated the	ROVIDER OR SUPPLIER ANA INC SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY PULL REGULATORY OR LSC IDENTIFYING INFORMATION) A Life Safety Code Recertification Survey was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.470(j). Survey Date: 07/07/15 Facility Number: 000947 Provider Number: 15G433 AIM Number: 100244580 At this Life Safety Code survey, REM-Indiana Inc. was found in compliance with Requirements for Participation in Medicaid, 42 CFR subpart 483.470(j), Life Safety From Fire, and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 33, Existing Residential Board and Care Occupancies. This one story facility was sprinklered. The facility has a fire alarm system with smoke detection in the corridors, common living areas and hard wired smoke detectors in all client seleping rooms. The facility has a fore alarm system with time of this survey. Calculation of the Evacuation Difficulty Score (E-Score) using NFPA 101 A, Alternative Approaches to Life Safety, Chapter 6, rated the	ROVIDER OR SUPPLIER ANA INC SUMMARY STATEMENT OF DEFICIENCIES (EACH OBERCIENCY MUST BE PRECEDED BY PULL REGULATORY OR LSC IDENTIFYING INFORMATION) INTITIAL COMMENTS A Life Safety Code Recertification Survey was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.470(j). Survey Date: 07/07/15 Facility Number: 100244580 At this Life Safety Code survey, REM-Indiana Inc. was found in compliance with Requirements for Participation in Medicaid, 42 CFR subpart 483.470(j). Life Safety Code (LSC), Chapter 33, Existing Residential Board and Care Occupancies. This one story facility was sprinklered. The facility has a fire alarm system with smoke detection in the corridors, common living areas and hard wired smoke detectors in all client sleeping rooms. The facility has a census of seven at the time of this survey. Calculation of the Evacuation Difficulty Score (E-Score) using NFPA 101 A, Alternative Approaches to Life Safety, Chapter 6, rated the	

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

(X6) DATE TITLE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

Facility ID: 000947